

**AZOMURES SA  
BIROUL MEDIU**

**VALORI MEDII ALE ANALIZELOR PENTRU APELE EPURATE LA IESIREA DIN STATIA DE EPURARE CRISTESTI  
FEBRUARIE 2020**

Parametrul	pH (unitati pH)	NH4+ (mg/l)	NO2- (mg/l)	NO3- (mg/l)	MTS (mg/l)	Ntotal (mg/l)	Ptotal (mg/l)	CBO5 (mg/l)	CCOCr (mg/l)	RF (mg/l)	Cloruri (mg/l)	Sulfati (mg/l)	Subst. extr. (mg/l)
<b>CMA conf. AGA 391/2016</b>	<b>6.5 - 8.5</b>	<b>3</b>	<b>2</b>	<b>37</b>	<b>35</b>	<b>15</b>	<b>2</b>	<b>25</b>	<b>125</b>	<b>2000</b>	<b>500</b>	<b>600</b>	<b>20</b>
<b>Val. medie</b>	<b>7,90</b>	<b>1,57</b>	<b>0,05</b>	<b>4,81</b>	<b>17,40</b>	<b>4,60</b>	<b>0,36</b>	<b>7,00</b>	<b>31,50</b>	<b>912,50</b>	<b>202,50</b>	<b>107,90</b>	<b>5,40</b>