

AZOMURES SA  
BIROUL MEDIU

VALORI MEDII ALE ANALIZELOR PENTRU APELE EPURATE LA IESIREA DIN STATIA DE EPURARE CRISTESTI  
Iunie 2020

Parametrul	pH (unitati pH)	NH4+ (mg/l)	NO2- (mg/l)	NO3- (mg/l)	MTS (mg/l)	Ntotal (mg/l)	Ptotal (mg/l)	CBO5 (mg/l)	CCOCr (mg/l)	RF (mg/l)	Cloruri (mg/l)	Sulfati (mg/l)	Subst. extr. (mg/l)
<b>CMA</b> <b>conf. AGA 391/2016</b>	<b>6.5 - 8.5</b>	<b>3</b>	<b>2</b>	<b>37</b>	<b>35</b>	<b>15</b>	<b>2</b>	<b>25</b>	<b>125</b>	<b>2000</b>	<b>500</b>	<b>600</b>	<b>20</b>
<b>Val. medie</b>	<b>8,12</b>	<b>0,47</b>	<b>0,13</b>	<b>17,58</b>	<b>24,60</b>	<b>7,20</b>	<b>0,45</b>	<b>6,00</b>	<b>30,70</b>	<b>943,00</b>	<b>136,00</b>	<b>152,00</b>	<b>3,60</b>