

**AZOMURES SA
BIROUL MEDIU**

**VALORI MEDII ALE ANALIZELOR PENTRU APELE EPURATE LA IESIREA DIN STATIA DE EPURARE CRISTESTI
AUGUST 2020**

Parametrul	pH (unitati pH)	NH4+ (mg/l)	NO2- (mg/l)	NO3- (mg/l)	MTS (mg/l)	Ntotal (mg/l)	Ptotal (mg/l)	CBO5 (mg/l)	CCOCr (mg/l)	RF (mg/l)	Cloruri (mg/l)	Sulfati (mg/l)	Subst. extr. (mg/l)
CMA conf. AGA 391/2016	6.5 - 8.5	3	2	37	35	15	2	25	125	2000	500	600	20
Val. medie	8,10	0,56	0,08	8,84	23,20	5,25	0,57	7,00	33,95	874,00	168,00	141,70	5,00