

AZOMURES SA
BIROUL MEDIU

VALORI MEDII ALE ANALIZELOR PENTRU APELE EPURATE LA IESIREA DIN STATIA DE EPURARE CRISTESTI
MARTIE 2021

| Parametrul | pH (unitati pH) | NH4+ (mg/l) | NO2- (mg/l) | NO3- (mg/l) | MTS (mg/l) | Ntotal (mg/l) | Ptotal (mg/l) | CBO5 (mg/l) | CCOCr (mg/l) | RF (mg/l) | Cloruri (mg/l) | Sulfati (mg/l) | Subst. extr. (mg/l) |
|---|--------------------|----------------|----------------|----------------|---------------|------------------|------------------|----------------|-----------------|----------------|-------------------|-------------------|------------------------|
| CMA conf. AGA 291/2020 | 6.5 - 8.5 | 3 | 2 | 37 | 35 | 15 | 2 | 25 | 125 | 2000 | 500 | 600 | 20 |
| Val. medie | 8.10 | 0.30 | 0.09 | 11.33 | 18.60 | 5.70 | 0.66 | 5.50 | 29.60 | 1142.50 | 261.50 | 158.00 | 4.20 |