

AZOMURES SA
BIROUL MEDIU

VALORI MEDII ALE ANALIZELOR PENTRU APELE EPURATE LA IESIREA DIN STATIA DE EPURARE CRISTESTI
APRILIE 2023

Parametrul	pH (unitati pH)	NH4+ (mg/l)	NO2- (mg/l)	NO3- (mg/l)	MTS (mg/l)	Ntotal (mg/l)	Ptotal (mg/l)	CBO5 (mg/l)	CCOCr (mg/l)	RF (mg/l)	Cloruri (mg/l)	Sulfati (mg/l)	Subst. extr. (mg/l)
CMA conf. AGA 291/2020	6.5 - 8.5	3	2	37	35	15	2	25	125	2000	500	600	20
Val. medie	7,20	1,95	0,10	0,87	28,20	2,40	0,23	17,00	54,60	332,50	68,12	26,80	6,30